



Bulk Asbestos Analysis

By Polarized Light Microscopy
EPA Method: 600/R-93/116 and
40 CFR, Part 763, Subpart E, App.E



Customer: JTL Services
3999 Sanderosa Rd.
Fayetteville, NC 28312

Attn: Jay Leonard

Lab Order ID: 10038366

Analysis: PLM

Date Received: 12/05/2023

Date Reported: 12/05/2023

Project: COF 0407-52-8846 949 Louise Circle
Fayetteville NC 28314

Sample ID	Description	Asbestos	Fibrous Components	Non-Fibrous Components	Attributes
Lab Sample ID	Lab Notes				Treatment
1	Sheetrock	None Detected		100% Other	Gray Non-Fibrous Homogeneous
10038366_0001					Crushed
2	Ceiling Surfacing	5% Chrysotile		95% Other	Beige Non-Fibrous Homogeneous
10038366_0002					Crushed
3	Ceiling Surfacing	5% Chrysotile		95% Other	Beige Non-Fibrous Homogeneous
10038366_0003					Crushed
4	Joint Compound	4% Chrysotile		96% Other	Tan Non-Fibrous Homogeneous
10038366_0004					Crushed
5	Joint Compound	4% Chrysotile		96% Other	Tan Non-Fibrous Homogeneous
10038366_0005					Crushed
6	Insulation	None Detected	99% Fiber Glass	1% Other	Transparent, Gray Fibrous Homogeneous
10038366_0006					Crushed, Teased
7	Felt Paper	None Detected	90% Cellulose	10% Other	Black, Brown Fibrous Homogeneous
10038366_0007					Dissolved, Teased
8	Shingles	None Detected	20% Fiber Glass	80% Other	Black Non-Fibrous Heterogeneous
10038366_0008					Crushed, Dissolved

Disclaimer: Due to the nature of the EPA 600 method, asbestos may not be detected in samples containing low levels of asbestos. We strongly recommend that analysis of floor tiles, vermiculite, and/or heterogenous soil samples be conducted by TEM for confirmation of "None Detected" by PLM. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government. Analytical uncertainty available upon request. Scientific Analytical Institute participates in the NVLAP Proficiency Testing program. Unless otherwise noted blank sample correction was not performed. Estimated MDL is 0.1%.

Lachlan Krenz (8)

Analyst

Approved Signatory



Company Contact Information	
Company: JTL Services LLC	Contact: Jay Leonard
Address: 3999 Sandevosa Road	Phone <input checked="" type="checkbox"/> : 910-237-3519
Fayetteville, NC 28312	Fax <input type="checkbox"/> :
	Email <input checked="" type="checkbox"/> : moldservicesjtl@aol.com

Asbestos Test Types	
PLM EPA 600/R-93/116 (PLM)	<input checked="" type="checkbox"/>
Positive stop	<input type="checkbox"/>
PLM Point Count 400 (PT4)	<input type="checkbox"/>
PLM Point Count 1000 (PTM)	<input type="checkbox"/>
PCM NIOSH 7400-A Rules (PCM)	<input type="checkbox"/>
B Rules (PCB) <input type="checkbox"/>	TWA (PTA) <input type="checkbox"/>
TEM AHERA (AHE)	<input type="checkbox"/>
TEM Level II (LII)	<input type="checkbox"/>
TEM NIOSH 7402 (TNI)	<input type="checkbox"/>
TEM Bulk Qualitative (TBL)	<input type="checkbox"/>
TEM Bulk Chatfield (TBS)	<input type="checkbox"/>
TEM Bulk Quantitative (TBQ)	<input type="checkbox"/>
TEM Wipe ASTM D6480-05	<input type="checkbox"/>
TEM Microvac ASTM D5755-02	<input type="checkbox"/>
TEM Water EPA 100.2 (TW1)	<input type="checkbox"/>
Other: _____	<input type="checkbox"/>

Billing/Invoice Information	Turn Around Times	
Company: Credit Card on File	90 Min. <input type="checkbox"/>	48 Hours <input type="checkbox"/>
Contact: COF-0407-52-8846	3 Hours <input type="checkbox"/>	72 Hours <input type="checkbox"/>
Address: 949 Louise Cir	6 Hours <input type="checkbox"/>	96 Hours <input type="checkbox"/>
Fayetteville NC	12 Hours <input checked="" type="checkbox"/>	120 Hours <input type="checkbox"/>
28314	24 Hours <input type="checkbox"/>	144+ Hours <input type="checkbox"/>

PO Number: _____
 Project Name/Number: _____

Sample ID #	Volume/Area	Comments
1		ceiling sheet rock
2		ceiling surface living room
3		ceiling surface Back Floor Bed room
4		ceiling joint compound kitchen
5		ceiling joint compound near bedroom
6		Attic Insulation
7		Roofing felt paper
8		Roofing shingle

Total # of Samples _____

Relinquished by	Date/Time	Received by	Date/Time
		CS	12/5
			10:30 AM

Accepted
 Rejected

1003B366

Client: JTL services LLC
Contact: Jay Leonard
Address: [Enter your street address here]
Phone: (910) 237-3519
Fax: [Enter fax here]
Email: moldservicesjtl@aol.com

Project: COF 0407-52-8846
 949 Louise Circle
Client Notes: Fayetteville NC 28314

P.O. #:
Date Submitted: 12/5/2023 0:00

Analysis: PLM
TurnAroundTime: 12

***Instructions:**
 Use Column "B" for your contact info

 To See an Example Click the
 bottom Example Tab.

 Enter samples between "<<" and ">>"
 Begin Samples with a "<<" above the first sample
 and end with a ">>" below the last sample.
 Only Enter your data on the first sheet "Sheet1"

 Note: Data 1 and Data 2 are optional
 fields that do not show up on the official
 report, however they will be included
 in the electronic data returned to you
 to facilitate your reintegration of the report data.

**Scientific
 Analytical
 Institute**


**4604 Dundas Drive
 Greensboro, NC 27407
 Phone: 336.292.3888
 Fax: 336.292.3313
 Email: lab@sailab.com**

<<

1 Ceiling Sheetrock	Sheetrock
2 Living room Ceiling surfacing	Ceiling Surfacing
3 Bedroom front back ceiling surfacing	Ceiling Surfacing
4 Kitchen ceiling joint compound	Joint Compound
5 Bedroom rear ceiling joint compound	Joint Compound
6 Attic Insulation	Insulation
7 Roofing felt paper	Felt Paper
8 Roofing shingles	Shingles

>>

Relinquished By

Received By