



**PURCHASING**

**September 26, 2025**

**MEMO TO:** Prospective Bidders  
**FROM:** Kimberly Toon, Purchasing Manager  
**SUBJECT:** Addendum #1: ITB-Tryon Drive Drainage Improvement  
**DUE DATE AND TIME:** SEPTEMBER 29, 2025; 2:00 p.m.

1. The Bid Documents are hereby modified per the attached Addendum #1 dated September 29, 2025. To include the following:

**a. Question & Answer:**

**Question:** I noticed that there is not a line item for Construction Staking, Will the City consider adding a line item for construction staking for the City of Fayetteville's work and add a line item for construction staking for PWC's work.

**Answer:** Section 01 31 00 paragraph 1.11 requires the Contractor to provide construction staking. Construction staking is considered incidental to the work and will not be measured or paid separately.

**Questions:** On the drainage plans, it shows 42" HDPE and 36" HDPE, can the City add a line for those items?

**Answer:** All proposed round pipes shall be RCP; quantities shown on the bid form include all pipe for the project. Revised plans, when issued, will be modified to show RCP as the proposed material.

**Question:** Line-item A-55, Permanent Seeding has 1 SY as a quantity, should that unit be in Acres?

**Answer:** Square Yards (SY) is the correct unit. The quantity required is 10,000 square yards.

**Question:** The provisions require the contractor to submit a vibration monitoring plan and submit monthly vibration reports. Once pipe installation, backfill, and compaction are finished in the foundation protection area near the houses, when can we close out vibration monitoring and reporting for each housing structure?

**Answer:** Vibration reporting adjacent to houses may be removed by the Contractor when both of the following are true:

1. All installation, backfill, compaction, and grading associated with adjacent improvements is completed
  2. Vibration monitors have registered zero (0) vibrations for a period of no less than 5 workdays
2. The foregoing changes shall be incorporated in the Bid Documents, and a copy of the Addendum #1, signed by the Bidder, must accompany the Bid to indicate the Bidder's familiarity with the changes.

**a. Question & Answer**

**Bidder Acknowledgement:**

Bidder Name (Print): \_\_\_\_\_

Bidder Signature: \_\_\_\_\_

Date of Signature: \_\_\_\_\_