



Monthly Fire Extinguisher Inspection List

Station: _____

Extinguisher #: _____

Year: _____

	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
Condition												
Proper Location												
Visible												
Accessible												
Clean												
Free of Damage												
Free of Corrosion/Rust												
Proper Gauge Reading												
Weight												
Nameplate Legible												
Safety Seals Intact												
Hose												
Free of Damage												
Coupling Intact												
Nozzle												
Clear of Obstruction												
Trigger Free to Operate												
Hydrostatic Test Date												
Nozzle Firmly Attached												
Inspector Initials												

Hydrostatic Testing Due: Every 12 Years for Dry Chemical, Every 5 Years for All Others