



Address Numbering Notice

Emergencies don't happen often, but when they do, it is important that emergency personnel find you within moments of your call. Without visible street numbers, emergency personnel can waste valuable time looking for your property.

This is a notice that your **residential** property is in violation of the City of Fayetteville Code of Ordinances Section 24-167 "Street Numbering." The identified violations have been checked below:

- Your numbers are not three inches in height and placed in a conspicuous place on the building so that it is visible from either the public or private street or the parking lot which serves the building.
- Your building is located more than 100 feet from the public street and/or hidden by natural brush, fencing, or barriers. The assigned street numbers must be posted at or near the property line by the driveway or the walkway.

Your **commercial** building may be in violation of the North Carolina Fire Prevention Code Section 505.1 "Address Identification." A fire inspector will be notified due to the following:

- Your numbers are not four inches in height and/or cannot be seen from the street or road fronting the property.
- The address numbers do not contrast with the background.
- Your building cannot be viewed from the public street or parking lot which serves the building and there is not a remote address number posted.

A fire inspector from the City of Fayetteville will revisit your property to verify that the information has been received and that the situation has been corrected. Failure to comply with the ordinance and code may result in a citation.

Date of Visit: _____ Fire Station/Unit#: _____

Name of FD Representative: _____

(Detach and Forward to Fire Prevention Office)

Name of FD Representative: _____

Station Number/Unit#: _____

Date/Time Notice was Left: _____

Address of Violation: _____

Where was notice left (if no one was present): _____

Who took delivery of notice (if anyone): _____



Address Numbering Notice

Emergencies don't happen often, but when they do, it is important that emergency personnel find you within moments of your call. Without visible street numbers, emergency personnel can waste valuable time looking for your property.

This is a notice that your **residential** property is in violation of the City of Fayetteville Code of Ordinances Section 24-167 "Street Numbering." The identified violations have been checked below:

- Your numbers are not three inches in height and placed in a conspicuous place on the building so that it is visible from either the public or private street or the parking lot which serves the building.
- Your building is located more than 100 feet from the public street and/or hidden by natural brush, fencing, or barriers. The assigned street numbers must be posted at or near the property line by the driveway or the walkway.

Your **commercial** building may be in violation of the North Carolina Fire Prevention Code Section 505.1 "Address Identification." A fire inspector will be notified due to the following:

- Your numbers are not four inches in height and/or cannot be seen from the street or road fronting the property.
- The address numbers do not contrast with the background.
- Your building cannot be viewed from the public street or parking lot which serves the building and there is not a remote address number posted.

A fire inspector from the City of Fayetteville will revisit your property to verify that the information has been received and that the situation has been corrected. Failure to comply with the ordinance and code may result in a citation.

Date of Visit: _____ Fire Station/Unit#: _____

Name of FD Representative: _____

(Detach and Forward to Fire Prevention Office)

Name of FD Representative: _____

Station Number/Unit#: _____

Date/Time Notice was Left: _____

Address of Violation: _____

Where was notice left (if no one was present): _____

Who took delivery of notice (if anyone): _____
